

## PRODUCT LIST NUMBERS & DESCRIPTION

### TWT ULTRA-VIOLET P.O.U. C SERIES DISINFECTION/PURIFICATION SYSTEM – See Section B3

| ITEM NUMBER       | GPM | PRODUCT DESCRIPTION:  | CASE/PACK |
|-------------------|-----|---|-----------|
| <b>UVC-250</b>    | 4   | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm & UV Monitor                             | 1         |
| <b>UVC-250-2</b>  | 4   | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm & UV Monitor                             | 1         |
| <b>UVC-700</b>    | 8   | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm & UV Monitor                             | 1         |
| <b>UVC-700-2</b>  | 8   | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm & UV Monitor                             | 1         |
| <b>UVC-1200</b>   | 12  | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automated Solenoid Valve | 1         |
| <b>UVC-1200-2</b> | 12  | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automated Solenoid Valve | 1         |
| <b>UVC-1500</b>   | 15  | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-1500-2</b> | 15  | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-3000</b>   | 30  | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-3000-2</b> | 30  | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-5000</b>   | 50  | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-5000-2</b> | 50  | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-6000</b>   | 100 | 120V / 60 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |
| <b>UVC-6000-2</b> | 100 | 230V / 50 Hz Ultraviolet System with Manual Shut-Off Valves, Alarm, UV Monitor and Automatic Solenoid Valve | 1         |

**Custom Orders:** Prices quoted upon request for larger systems.

**GPM:** Gallons per minute.

**Case Pack:** All units packed individually.

**Replacement Lamps:** Generally lamps should be replaced every 10 to 12 months, depending on water use quality and conditions